


FIRE ALARM REQUIREMENTS FOR GROUP R OCCUPANCIES



M



M



M



M

NOTES

Grid of dotted lines for notes.

MEYERFIRE UNIVERSITY | FA101.01F



2021 International Building Code (IBC)

310.4 Residential Group R-3.
 Residential Group R-3 occupancies where the occupants are generally permanent in nature and not classified as Group R-1, R-2, R-2.1, R-2.2, R-2.3, R-2.4 or U-1, including buildings that do not contain more than five dwelling units.
 Care facilities that provide accommodations for five or fewer persons receiving care.
 Congregate living facilities (apartments) with 16 or fewer occupants.
 Boarding houses (apartments).
 Convents.
 Dormitories.
 Fraternal and societies.
 Mansions.
 Monasteries.
 Congregate living facilities (apartments) with 16 or fewer occupants.
 Boarding houses (apartments).
 Congregate living facilities with five or fewer guest rooms and 10 or fewer occupants.

310.4.1 Care facilities within a dwelling.
 Care facilities for five or fewer persons receiving care that are within a single family dwelling are permitted to comply with the International Residential Code provided an automatic sprinkler system is installed in accordance with Section 903.3.1.3 or Section F903.4 of the International Residential Code.

310.4.2 Lodging houses.
 Dwelling occupied lodging houses with five or fewer guest rooms and 10 or fewer total occupants shall be permitted to be constructed in accordance with the International Residential Code, provided that an automatic sprinkler system is installed in accordance with Section 903.3.1.3 or Section F903.4 of the International Residential Code.

310.5 Boarding Group R-4.
 Residential Group R-4 occupancy shall include buildings, structures or portions thereof for more than five but not more than 16 persons, excluding staff, who reside on a 24-hour basis in a supervised residential environment and receive



NOTES

A large area of dotted lines for taking notes.