WHEN CAN I USE NFPA 13D?

STANDARDS OF SPRINKLER DESIGN BY MEYERFIRE UNIVERSITY | NOVEMBER 2021

SUMMARY

When can I use NFPA 13D?

- Limited by the Local Adopted Building Code:
 - Always review the adopted building code and NFPA 13D edition to verify when you can use an NFPA 13D system. These requirements
 are constantly changing.
- Limits within Applicable Building Code:
 - NFPA 13D permitted only for R-3, R-4 Condition 1, or Care Facilities with five or fewer individual in a single-family dwelling.
- Limits within NFPA 13D:
 - Chapter 1 of NFPA 13D states that the standard only covers sprinkler systems in one- and two- family dwellings and manufactured homes and townhouses. If a townhouse is not properly fire-separated, or has three or more dwelling units, an NFPA 13D system cannot be used under the limits of NFPA 13D.

Why are there **limitations** to when an NFPA 13D system can be used?

- NFPA 13D systems are the least restrictive standard pertaining to the installation of sprinkler systems.
- The intent of the sprinkler system is to increase time for evacuation of one- or two-family homes with the most economical approach; it is not intended for property protection nor is it suitable for more hazardous fires.



One- and Two- Family Homes
Limited to R-3, R-4 Condition 1,
and Care Facilities with five or fewer individuals



Goal: Life Safety Only

Designed to provide adequate time for evacuation, not for property protection or overly hazardous content

CODE/STANDARD REFERENCES





NFPA 13D – Standard for the Installation of Sprinkler Systems in One- and Two- Family Dwellings and Manufactured Homes IBC – 2021: International Building Code

VIDEO LINK

www.meyerfire.com/university/when-can-i-use-nfpa-13d

GET MORE LIKE THIS

This page is from MeyerFire University. Get updates & more here: Join MeyerFire University | Course & Video Catalog | Video Library

