



DIFFERENCE BETWEEN PRESSURE AND HEAD?




M



M



M




M

NOTES

A large area of dotted lines for taking notes.

WATER SUPPLY: 20 PSI
 PUMP: 100-FT HEAD




WATER SUPPLY: 20 PSI (1.4 BAR)
 PUMP: 100-FT HEAD (30.5 M)
 HEIGHT TO 3RD FLOOR: 35-FT (10.7 M)

CONVERT PUMP HEAD TO PRESSURE:
 $0.433 \text{ PSI/FT} \times 100\text{-FT HEAD} = 43.3 \text{ PSI}$ (NET PUMP PRESSURE)

PRESSURE AT PUMP DISCHARGE:
 $20 \text{ PSI} + 43.3 \text{ PSI} = 63.3 \text{ PSI}$ (AT PUMP DISCHARGE)

CONVERT BUILDING HEIGHT TO PRESSURE LOSS:
 $0.433 \text{ PSI/FT} \times 35\text{-FT} = 15.2 \text{ PSI}$ (ELEVATION LOSS)

PRESSURE AT THIRD LEVEL:
 $63.3 \text{ PSI} - 15.2 \text{ PSI}$




WATER SUPPLY: 20 PSI (1.4 BAR)
 PUMP: 100-FT HEAD (30.5 M)
 HEIGHT TO 3RD FLOOR: 35-FT (10.7 M)

CONVERT CITY PRESSURE TO HEAD:
 $1.4 \text{ BAR} / 0.098 \text{ BAR/M} = 14.3 \text{ M HEAD}$ (NET PUMP HEAD)

HEAD AT PUMP DISCHARGE:
 $14.3 \text{ M} + 30.5 \text{ M} = 44.7 \text{ M HEAD}$ (AT PUMP DISCHARGE)

HEAD AT THIRD LEVEL:
 $44.7 \text{ M HEAD} - 10.7 \text{ M HEAD} = 34 \text{ M HEAD}$ (HEAD AT THIRD LEVEL)
 $34 \text{ M HEAD} = 3.3 \text{ BAR}$



DIFFERENCE BETWEEN PRESSURE AND HEAD:

- ① GAUGE PRESSURE IS A SYSTEM PRESSURE WITHOUT CONSIDERATION OF ATMOSPHERIC PRESSURE
- ② ABSOLUTE PRESSURE DOES CONSIDER ATMOSPHERIC PRESSURE
- ③ HEAD PRESSURE IS THE EQUIVALENT HEIGHT OF A COLUMN OF WATER TO CREATE AN EQUIVALENT GAUGE PRESSURE



NOTES

Grid area for notes.