


# SPRINKLER SCHEDULE - COVERED PATIO

New	Count	Type	Coverage	K-Factor	Response	Orifice	Deflector	Finish
▲	3	DRY HSW	Standard	5.6	Quick	1/2"	4" FROM CEIL	CHROME
Total: 3								


1

## REVISIONS


NO.	DATE	REVISION
1	03/03/2023	Revised Layout



**COVERED PATIO - FLOOR PLAN**  
SCALE: 1/4" = 1'-0"  
NORTH



**COVERED PATIO - RCP**  
SCALE: 1/4" = 1'-0"  
NORTH



**D COVERED PATIO - SECTION**  
SCALE: 3/8" = 1'-0"

**RESTAURANT**  
NEW CONSTRUCTION  
MEYERFIRE UNIVERSITY

NUMBER: 21134

STATUS: REVIEW SET

DATE: 03/02/2023

SHEET:

COVERED PATIO

**FP4**