


SPRINKLER SCHEDULE - COVERED PATIO

New	Count	Type	Coverage	K-Factor	Response	Orifice	Deflector	Finish
▲	2	DRY HSW	Standard	5.6	Quick	1/2"	4" FROM CEIL	CHROME
Total: 2								


1 2

REVISIONS


NO.	DATE	REVISION
1	03/03/2023	Revised Layout
2	03/04/2023	Revised Layout



COVERED PATIO - FLOOR PLAN
SCALE: 1/4" = 1'-0"
NORTH



COVERED PATIO - RCP
SCALE: 1/4" = 1'-0"
NORTH



D COVERED PATIO - SECTION
SCALE: 3/8" = 1'-0"

RESTAURANT
NEW CONSTRUCTION
MEYERFIRE UNIVERSITY

NUMBER: 21134

STATUS: REVIEW SET

DATE: 03/02/2023

SHEET:

COVERED PATIO

FP4

3/2/2023 1:22:55 PM